



DELHI STATE CANCER INSTITUTE

-a centre par excellence in the service of humanity
(an autonomous institution under the Govt. of NCT of Delhi)
Dilshad Garden, Delhi 110 095 (India)

TeleFax: +91-11-2211 0505 E-mail: dsci.delhi@yahoo.co.in Web: www.dsci.nic.in

(Office of the Chief Engineer, DSCI)

NO.F.7 (16)/DSCI/CE/2009-10/492

Date: 10/01/12

NOTICE INVITING QUOTATION

Sealed Item rate quotations are invited from Electrical contractors registered in CPWD so as to reach the undersigned on or before 19/01/2012 at 3:00 P.M as per schedule of quantities and terms & conditions given below. The quotations shall be opened on the same day at 3:30 P.M

Name of Work: Reinstallation of 2 X 380 KVA D.G sets at the new location at Delhi State Cancer Institute, Dilshad Garden, Delhi

Estimated Cost : Rs. 495968.00

Terms & Conditions:-

1. Time allowed is 15 days.
2. The Quotation must be in sealed cover addressed to CE, DSCI Delhi
3. Deptt reserves the right to reject the quotation without assigning any reasons.
4. Necessary recoveries shall be made from contractor as per statutory norms.
5. Contractor has to carry out the work as per programme given by Engineer In charge.
6. Contractor has to carry out the work as per programme given by Engineer In charge & in accordance with CPWD General Specification for electrical works Part-I (Internal) & part-II (external).
7. Contractor should have PAN No. & Tin no.
8. Quoted rates shall be inclusive of all taxes & duties and nothing extra shall be paid on this account.
9. Materials to be used in the work shall have to be got approved by the Engineer-in-charge or his representative before use at site
10. Contractor shall be responsible for watch and ward of materials.
11. Site shall be cleared after completion of work.
12. Work has to be carried out as per convenience of hospital timing (odd hours) & also working on holidays as decided by the hospital authorities without any extra financial or other benefit.
13. NIQ is available on websites www.dsci.nic.in

**Chief Engineer
DSCI**

Name of Work: Reinstallation of 2 X 380 KVA D.G Sets at the new location at Delhi State Cancer Institute, Dilshad Garden, Delhi

Sl. No.	Description	Qty	Rate	Amount
1.	Earthing with G.I earth plate 600 mm X 600 mm X 6mm thick i/c accessories and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc (but without charcoal or coke and salt) as required.	03 set		
2.	Extra for using salt and charcoal for G.I or copper plate earth. Electrode as required	6 set		
3.	Earthing with copper earth plate 300mm X 300mm X 3mm thick i/c accessories and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc (but without charcoal or coke and salt) as required).	3 set		
4.	Earthing with G.I earth pipe 4.5 mtr long 40 mm dia i/c accessories and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc (But without charcoal or coke and salt) as required.	02 set		
5.	Extra for using salt and charcoal for pipe earth electrode as required	02 set		
6.	Providing and fixing 25 mm X 5mm G.I strip in 40 mm dia G.I pipe from earth electrode as required.	20 mtr		
7.	Providing and fixing 25mm X 5mm copper strip in 40 mm dia copper pipe from earth electrode as required.	25 mtr		
8.	Supplying and laying of one number PVC insulated and PVC sheathed/XLPE power cable of size 3 ½ X 240 sq mm, aluminium conductor armed cable direct in ground including excavation, sand cushioning, protective covering and refilling the trench etc as required.	215 mtr		
9.	Supplying and making end termination with brass compression gland and aluminium lugs for the following size of PVC insulated and PVC sheathed/XLPE aluminium conductor cable of 1.1 KV grade as required. (a) 3 ½ X 120 sq mm (b) 3 ½ X 240 sq mm	02 no. 04 no.		
10.	Supplying and making straight through cable jointing with heat shrinkable jointing kit complete with all accessories i/c ferrules suitable for following size of 3 core, XLPE aluminium conductor cable of 11 KV grade as required (a) 3 ½ X 240 sq. mm	2 no.		
Total				

**Chief Engineer
DSCI**